

RESOLUTION NO. 109

WHEREAS, pursuant to study and recommendations of the District Engineers, it would appear that certain safeguards should be required of all new industrial and commercial construction; and


WHEREAS, a back flow prevention valve is a reasonable and proper requirement to safeguard the District and its public users, NOW, THEREFORE,

BE IT RESOLVED by the Board of Commissioners, East Wenatchee Water District, Douglas County, Washington, as follows:

1. That on all new commercial or industrial construction to be served by the East Wenatchee Water District, or on any modified, improved, altered or repaired services to existing commercial or industrial customers, or any change in use, function or requirements of any such existing commercial or industrial customer, a back flow prevention valve shall be installed by said customer or at the expense of said customer as a condition of providing domestic water service to said customer.

2. This requirement may be temporarily or conditionally waived by the Board from time to time upon application of said customer under circumstances and conditions safeguarding the interests of the District and consistent with the use and intentions of said back flow prevention facility.

ADOPTED this 22nd day of February 1972, by the Board of Commissioners of East Wenatchee Water District, Douglas County, Washington, at a regular meeting thereof.

  
\_\_\_\_\_  
President

Attest:

\_\_\_\_\_  
Secretary