

ABANDONMENT, REMOVAL, AND TERMINATION NOTES

DISTRICT SHALL BE SOLE DETERMINER OF APPROPRIATE ABANDONMENT PROCEDURES AND METHODS. RESTORE ALL DISTURBED SURFACES TO ORIGINAL CONDITION AND TO THE SATISFACTION OF THE DISTRICT. DELIVER, UNDAMAGED, ALL REMOVED EQUIPMENT (HYDRANTS, SERVICE BRASS, VALVES, ETC., NOT PIPE) TO THE DISTRICT AT THE 15TH STREET AND EASTMONT SHOP WITHIN ONE WEEK OF REMOVAL. THE DISTRICT OWNS ALL EXISTING MATERIALS AND HAS THE RIGHT OF SALVAGE FOR ANY EQUIPMENT AT THEIR DISCRETION. ANY EQUIPMENT THE DISTRICT DOES NOT WISH RETURNED SHALL BE DISPOSED OF BY THE CONTRACTOR. SHOULD THE CONTRACTOR UNNECESSARILY DAMAGE ANY EXISTING FUNCTIONAL EQUIPMENT, SAID EQUIPMENT SHALL BE REPLACED BY THE CONTRACTOR AT THEIR COST. THE FOLLOWING METHODS ARE APPROVED ABANDONMENT PROCEDURES FOR TERMINATED EQUIPMENT.

ABANDONED HYDRANTS, SERVICES, BRANCH MAINS, ETC. SHALL BE TERMINATED AT THE FACILITY LOCATION AND AT THE MAINLINE. THE LATERAL SHALL NOT BE LEFT CONNECTED TO THE MAINLINE.

VALVES

1. REMOVE VALVES AND VALVE BOXES. PLUG OR BLIND FLANGE THE WATER MAIN.
2. AN ALTERNATIVE METHOD OF ABANDONMENT IS ACCEPTABLE IF, AT THE DISCRETION OF THE DISTRICT, THE VALVE CANNOT BE REMOVED. PLUG AND CLOSE THE VALVE, THEN REMOVE THE VALVE BOX.

WATER MAINS

1. CUT AND DRAIN THE ABANDONED WATER MAIN WHERE EXPOSED DURING CONSTRUCTION AND AT ALL LOW POINTS.
2. REMOVE MAINS IN THE WAY OF NEW CONSTRUCTION. SAW CUT AND REMOVE SHORT SECTIONS OF PIPE. MAINS SHALL NOT BE FORCIBLY REMOVED WITH HEAVY EQUIPMENT DUE TO POTENTIAL DAMAGE TO SURROUNDING UTILITIES.
3. MAINS THAT WILL BE TERMINATED BUT NOT ENCOUNTERED DURING NEW TRENCHING MAY BE LEFT IN PLACE, BUT ALL VALVES MUST BE REMOVED OR ABANDONED AS DESCRIBED UNDER "VALVES".
4. PLUG ENDS OF ABANDONED MAINS EXPOSED DURING CONSTRUCTION WITH GROUT PLUG, BLIND FLANGE, OR CAP AS DIRECTED BY THE DISTRICT DEPENDING ON THE TYPE OF PIPE AND SOIL CONDITIONS.

WATER SERVICES AND AIR VALVE ASSEMBLIES

1. REMOVE ALL VAULTS, SETTERS AND MISCELLANEOUS FITTINGS. BACKFILL WITH CRUSHED ROCK AND COMPACT. NATIVE SOILS MAY BE USED FOR BACKFILL ONLY IF APPROVED BY THE DISTRICT.
2. CUT SERVICE AT MAIN AND REMOVE STUB FROM CORP STOP. CLOSE CORP STOP AND INSTALL THREADED CAP.
3. REMOVE ENTIRE SERVICE LINE BACK TO WATER MAIN (EXCAVATE OR PULL).
4. AT THE DISCRETION OF THE DISTRICT, THE SERVICE LINE MAY REMAIN IN PLACE, BUT MUST BE TERMINATED AT THE MAINLINE AS DESCRIBED IN ITEM 2.

HYDRANTS

1. REMOVE ENTIRE HYDRANT. REMOVE OR ABANDON LATERAL PIPE AND ISOLATION VALVE AS DETAILED ABOVE.
2. REMOVE ANY BOLLARDS.
3. BACKFILL WITH CRUSHED ROCK, OR NATIVE MATERIAL IF APPROVED BY THE DISTRICT.



East Wenatchee Water District

WATER SYSTEM STANDARD DETAIL

COPYRIGHT 2025 EAST WENATCHEE WATER DISTRICT. MAY BE REPRODUCED UNMODIFIED FOR DISTRICT PROJECTS. OTHER REPRODUCTION OR USE WITHOUT THE DISTRICT'S WRITTEN CONSENT IS PROHIBITED.

ABANDONMENT AND REMOVAL OF TERMINATED FACILITIES

FILENAME: EWD TW29

REVISED: JAN 7, 2020

DRAWING No. W-15

SHEET No. 28