

RESOLUTION No. 250

AUTHORIZING ADDITIONAL PUMPING CAPACITY OF 19th St. Well


WHEREAS, the East Wenatchee Water District has an existing well in operation for domestic use at 19th and Cascade Streets, and

WHEREAS, said well is capable of producing additional water by enlarging its present pumping capacity, and

WHEREAS, the District has consulted with its engineers relative to this matter, and it has been determined that said well will increase its present pumping capacity to approximately 1350 gallons per minute from the present 900 gallons per minute.

THEREFORE BE IT HEREBY RESOLVED that the BOARD OF COMMISSIONERS of the EAST WENATCHEE WATER DISTRICT hereby authorize Wells and Wade Hardware, Wenatchee, Washington to proceed with the necessary materials to enlarge said pump from a quote received on August 11, 1978 in the amount of Two Thousand Four Hundred Sixty Five Dollars and no Cents (\$2,465.00).

ADOPTED, this 25th day of September, 1978 by the Board of Commissioners of the East Wenatchee Water District, Douglas County, Washington at a regular meeting thereof.

  
\_\_\_\_\_  
J. Clyde Ballard, President

ATTEST:

  
\_\_\_\_\_  
Paul W. Blanchard, Secretary

/sf