

RESOLUTION NO. 487

EMERGENCY RESOLUTION TO INSTALL WATER MAIN ON  
KENTUCKY FROM NE 10<sup>TH</sup> STREET TO NE 8<sup>TH</sup> STREET DUE TO  
LEAKING MAIN

WHEREAS, the East Wenatchee Water District has attempted to make repairs to the existing 8 inch steel main but as one is repaired another is found. The District crews in one night (10-13-99) used up all the repair bands (14) that they had in inventory and then had to quit and reenergize the old main even though it still leaked, and


WHEREAS, the District's comprehensive plan identifies this improvement to be constructed in the future, and

WHEREAS, this improvement will replace the existing 8 inch and 12 inch water mains currently serving the area, and

WHEREAS, it is deemed to be in the best interest of the Water District to declare this project as an Emergency and proceed to procure materials and complete the project in a timely manner with equipment and labor being provided by a local contractors.

NOW THEREFORE, BE IT HEREBY RESOLVED by the BOARD OF COMMISSIONERS of the EAST WENATCHEE WATER DISTRICT, that Resolution No. 487 is hereby declared an Emergency and further authorizes the manager to proceed with whatever is necessary to install the water main and appurtenances.

ADOPTED, this 19<sup>th</sup> day of October, 1999, by the BOARD OF COMMISSIONERS of the East Wenatchee Water District, Douglas County, Washington at a regular meeting thereof.

  
Mike McCourt, President

ATTEST:

  
Howard Laughery, Secretary