

**RESOLUTION NO. 644**

**EMERGENCY RESOLUTION FOR MAIN REPLACEMENT 5<sup>TH</sup> ST NE NORTH  
NILE AVE TO NORTH PERRY AVE**

WHEREAS, the East Wenatchee Water District has attempted to make repairs to the existing 6 inch old steel main, and

WHEREAS, the crew has continued to try to repair the main and the main continues to leak, and


WHEREAS, it is deemed to be in the best interest of the District to declare this project as an Emergency and proceed to procure approximately 1,300 feet of 8" ductile iron pipe material and associated parts and replace the existing pipe, and


WHEREAS, due to the number and severity of leaks in the old pipe, there is a health and safety concern and there is not adequate time to have the project bid and completed before October 15, 2013, therefore the Commissioners conclude it is an Emergency repair project, and

WHEREAS, it is in the best interest of the District to use its own crew to replace said waterline, and

NOW THEREFORE, BE IT HEREBY RESOLVED by the BOARD OF COMMISSIONERS of the EAST WENATCHEE WATER DISTRICT that the watermain replacement project on 5<sup>th</sup> ST NE between Nile and Perry be deemed as an Emergency.

ADOPTED, this 4th day of September, 2013, by the BOARD OF COMMISSIONERS of the East Wenatchee Water District, Douglas County, Washington at a regular meeting thereof.

  
\_\_\_\_\_  
Mike McCourt, President

ATTEST:  
  
\_\_\_\_\_  
Terry Barnes, Secretary