

ORIGINAL

RESOLUTION NO. 824

EMERGENCY RESOLUTION FOR GRANT ROAD CORROSION

WHEREAS, the East Wenatchee Water District has discovered corrosion in the majority of existing piping and valving appurtenances on Grant Road between North Georgia Ave and North Kentucky Ave, and

WHEREAS, the corrosion is in the advanced stages and there is a health and safety concern, and


WHEREAS, due to the severity of the corrosion, there is not sufficient time to bid the project, and

WHEREAS, it is in the best interest of the District to use its own crew to repair said appurtenances with cathodic protection , and

WHEREAS, in accordance with RCW 39.04.280, the District has deemed this project as an Emergency

NOW THEREFORE, BE IT HEREBY RESOLVED by the BOARD OF COMMISSIONERS of the EAST WENATCHEE WATER DISTRICT deem the Grant Road corrosion as an Emergency project.

ADOPTED, this 3rd day of April, 2024, by the BOARD OF COMMISSIONERS of the East Wenatchee Water District, Douglas County, Washington at a regular meeting thereof.


Tracy Peterson, President

ATTEST:


Terry Barnes, Secretary